



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NW-6330AT2061

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Hans Sasserath GmbH & Co. KG Mühlenstraße 62, D-41352 Korschenbroich
Distributor <i>Vertreiber</i>	Hans Sasserath GmbH & Co. KG Mühlenstraße 62, D-41352 Korschenbroich
Product Category <i>Produktart</i>	Valves for drinking water: cold water pressure reducing valve (6330)
Product description <i>Produktbezeichnung</i>	cold water pressure reducing valve
Model <i>Modell</i>	314.1; 314.S; 314.N; 4315; 315; 315 AB; 315.1; 315.2; 312; 6247
Test reports <i>Prüfberichte</i>	Laboratory control test: 2-0013/23 TO1 from 24.11.2023 (TZW) Laboratory control test: 2-0195/21 from 05.01.2022 (TZW) Supplement test: DM 018/19 from 08.11.2019 (TZW) Supplement test: DM 001/18 from 06.08.2018 (TZW) Supplement test: DM 002/14 from 03.08.2015 (TZW)
Test basis <i>Prüfgrundlagen</i>	DVGW W 570-1 (01.03.2013) DIN EN 1567 (01.01.2000) UBA BWGL-Metalle: Grundwerkstoffe (11.01.2023) UBA KTW-BWGL (07.03.2022) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	21.12.2028 / 24-0347-WNR

02.05.2024 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
312	Noise emission class: I Pressure rating: PN 16 Nominal diameter: DN 10	
314.1; 314.S; 314.N; 4315; 315; 315 AB; 315.1; 315.2	Noise emission class: I / II Pressure rating: PN 16 Nominal diameter: DN 15	
4315; 315; 315 AB; 315.1; 315.2	Noise emission class: I / II Pressure rating: PN 16 Nominal diameter: DN 20	
4315; 315; 315 AB; 315.2	Noise emission class: I Pressure rating: PN 16 Nominal diameter: DN 25	
4315; 315; 315 AB; 315.2	Noise emission class: I Pressure rating: PN 16 Nominal diameter: DN 32	
4315; 315; 315 AB; 315.2	Pressure rating: PN 16 Nominal diameter: DN 40	
4315; 315; 315 AB; 315.2	Pressure rating: PN 16 Nominal diameter: DN 50	
6247	Pressure rating: PN 16 Nominal diameter: DN65	
6247	Pressure rating: PN 16 Nominal diameter: DN 80	
6247	Pressure rating: PN 16 Nominal diameter: DN 100	

Type Variation Ausführungsvariante	Explanations Erläuterungen
312	on both sides internal thread
314.1; 314.S; 314.N; 315.1	inlet side: external thread, outlet side: connection adapter only in combination with a drinking water safety unit
315; 315 AB; 4315; 315.2	inlet and outlet side: threaded connection with external thread
6247	with flang connections

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

ABP for types:

312: P-IX 6736/I (noise class I: DN 10)
 314.1: P-IX 7636/I (noise class I: DN 15)
 314.S: P-IX 16708/I (noise class I: DN 15)
 314.N; P-IX 16867/II (noise class II; DN 15)
 315 and 315 AB: P-IX 7635/I (noise class I: DN 15, DN 20, DN 25)
 315 and 315 AB: P-IX 7729/I (noise class I: DN 32)
 315.1: P-IX 16742/I (noise class I: DN 15, DN 20)
 315.2: P-IX 6902/I (noise class I: DN 15, DN 20, DN 25, DN 32)
 4315: P-IX 7905/I (noise class I: DN 15, DN 20, DN 25, DN 32)

DN 15